




**SOLAR ENERGY  
TECHNOLOGIES OFFICE**  
U.S. Department Of Energy

## Sodium receiver

Gen3 CSP Summit  
August 25, 2021

Joe Coventry  
Chief Investigator  
Australian National University





**Australian Government**  
**Australian Renewable  
Energy Agency**

NREL Award # 34209 (agreement number)

# Commercial sodium receiver

- “Conventional” cylindrical sodium receiver concept, similar molten salt receivers

- System design output 50 MW<sub>e</sub>
- Solar multiple ~3.0
- Temperature range: 520°C to 740°C.
- Receiver 14.5 m high x 14 m diam.
- Nominal receiver output: 350 MW<sub>th</sub>





# Performance Summary

- Receiver sizing based on annual performance simulation
- Flow-path adapted to liquid sodium properties
- Flux controlled to remain below limits determined by creep-fatigue behaviour of the tube material <sup>(1)</sup>
- Efficiency consistently high throughout the year

Design point

	Summer			Equinox				Winter		
	Noon	Noon +2h	Noon +6	Noon	Noon +2h	Noon +4h	Noon +5h	Noon	Noon +2h	Noon +4h
DNI (W/m <sup>2</sup> )	950	930	520	980	950	805	590	930	875	510
Field efficiency	0.647	0.632	0.416	0.639	0.618	0.539	0.420	0.590	0.562	0.369
Intercept efficiency	0.978	0.972	0.962	0.968	0.955	0.961	0.957	0.952	0.957	0.950
Solar absorption efficiency	0.987	0.987	0.987	0.987	0.987	0.987	0.987	0.987	0.987	0.987
Thermal efficiency	<b>0.923</b>	<b>0.924</b>	<b>0.830</b>	<b>0.921</b>	<b>0.922</b>	<b>0.906</b>	<b>0.846</b>	<b>0.920</b>	<b>0.913</b>	<b>0.792</b>
Receiver efficiency	0.912	0.912	0.819	0.909	0.910	0.895	0.835	0.908	0.901	0.782
Receiver and intercept efficiency	0.891	0.886	0.788	<b>0.881</b>	0.869	0.860	0.799	0.865	0.862	0.743
Overall efficiency	0.577	0.560	0.328	0.563	0.537	0.463	0.335	0.511	0.484	0.274





# Sodium in industry

## Sodium is a commodity


- Sodium production and consumption is well over 100,000 tonnes/year, mainly in China
- Chemical uses
  - A substantial amount is used in sodium alkyl sulfates as the principal ingredient in synthetic detergents
  - Manufacture of indigo dyes, for dyeing cotton along with manufacturing denim
  - Deoxidant and reducing agent for producing Ca, Zr, Ti and other transition metals
- Largest producers are Nippon Soda, Lantai, Wanji, Yinchuan, Tiantai, and MSSA

Oil desulfurization  
Potassium Production  
Sodium Aluminum Hydride  
Paper bleaching  
Polymer production (EPDM)  
PCB destruction  
Solvent production (glymes)  
Reagent for pharmaceuticals  
PTFE Etchant  
Catalyst in oil refining  
Sodium Methyate

[energy.gov/solar-office](https://energy.gov/solar-office)


## Sodium in nuclear

- Since the 1950s RD&D in power generation has been linked to funding for Fast Breeder Reactor (FBR) programs
- Today sodium-cooled FBRs operate in Russia, India and China
- Overall there are over 400 years cumulative operation of sodium-cooled FBRs in plants at scales of 10s to 100s of MWe
- Sodium is a safe heat transfer fluid to use when handled properly



# System components


- Key sodium components are available commercially
  - Sump tank
  - Inlet vessel
  - Purification skid (cold trap)
  - Argon tank, cryogenic tank, atmospheric heater
  - 4 x 33% pump configuration, each 4-stages
- Shorter towers may provide cost reduction opportunities




energy.gov/solar-office

- Details of the capital cost breakdown in the final report [NREL/TP-5700-79323](https://www.nrel.gov/docs/fy16osti/67923.pdf)

Do not distribute beyond project team.




*Sodium loop components (source: John Cockerill)*





*spb compared several tower designs*

# De-risking by testing


- Sodium receiver operation is not new *however* successful demonstration is required at the Gen3 CSP temperatures
- A 1 MWth “billboard” style receiver was designed for Phase 3
- The Australian Solar Thermal Research Institute (ASTRI) is planning to test a 740°C prototype sodium receiver in 2022



*The 1 MWth receiver and sodium loop designed for Phase 3 prototype testing at Sandia National Laboratories*



*The 700 kWth ‘Mark 1’ receiver to be tested in 2022 by ASTRI at CSIRO Newcastle, will operate at a temperature range compatible with next-generation CSP (520-740°C)*



Source: ABC News



# Thank you!

Associate Professor Joe Coventry  
Solar Thermal Group, School of Engineering  
Australian National University  
T +612 6125 2643  
E [joe.coventry@anu.edu.au](mailto:joe.coventry@anu.edu.au)

## Acknowledgement

I would like to acknowledge the contributions of all the Australian (ASTRI) team who contributed to the Gen3 Liquids Pathway project, included John Pye, Charles-Alexis Asselineau, Felix Venn, William Logie, Armando Fontalvo, Shuang Wang, Robbie McNaughton, Daniel Potter, Theodore Steinberg and Geoffrey Will.

ANU's sodium research is supported by the Australian Solar Thermal Research Institute (ASTRI), a program supported by the Australian Government through the Australian Renewable Energy Agency (ARENA)




**SOLAR ENERGY**  
**TECHNOLOGIES OFFICE**  
U.S. Department Of Energy

**Backup slides**





# Commercial-Scale Sodium Receiver Performance Summary

	Summer			Equinox				Winter		
	Noon	Noon +2h	Noon +6	Noon	Noon +2h	Noon +4h	Noon +5h	Noon	Noon +2h	Noon +4h
DNI (W/m <sup>2</sup> )	950	930	520	980	950	805	590	930	875	510
Field utilization	0.882	0.926	1.000	0.877	0.937	1.000	1.000	1.000	1.000	1.000
Field efficiency	0.647	0.632	0.416	0.639	0.618	0.539	0.420	0.590	0.562	0.369
Intercept efficiency	0.978	0.972	0.962	0.968	0.955	0.961	0.957	0.952	0.957	0.950
Solar absorption efficiency	0.987	0.987	0.987	0.987	0.987	0.987	0.987	0.987	0.987	0.987
Thermal efficiency	<b>0.923</b>	<b>0.924</b>	<b>0.830</b>	<b>0.921</b>	<b>0.922</b>	<b>0.906</b>	<b>0.846</b>	<b>0.920</b>	<b>0.913</b>	<b>0.792</b>
Receiver efficiency	<b>0.912</b>	<b>0.912</b>	<b>0.819</b>	<b>0.909</b>	<b>0.910</b>	<b>0.895</b>	<b>0.835</b>	<b>0.908</b>	<b>0.901</b>	<b>0.782</b>
Receiver and intercept efficiency	<b>0.891</b>	<b>0.886</b>	<b>0.788</b>	<b>0.881</b>	<b>0.869</b>	<b>0.860</b>	<b>0.799</b>	<b>0.865</b>	<b>0.862</b>	<b>0.743</b>
Overall efficiency	<b>0.577</b>	<b>0.560</b>	<b>0.328</b>	<b>0.563</b>	<b>0.537</b>	<b>0.463</b>	<b>0.335</b>	<b>0.511</b>	<b>0.484</b>	<b>0.274</b>
Spillage loss (MW <sub>th</sub> )	8.78	10.93	6.17	12.58	17.96	12.48	7.97	19.26	15.70	7.09
Solar power through aperture (MW <sub>th</sub> )	384.0	384.1	154.2	385.1	383.8	307.8	176.2	383.0	346.6	133.7
Solar reflection loss (MW <sub>th</sub> )	4.92	4.93	1.98	4.94	4.92	3.95	2.26	4.91	4.44	1.71
Emission loss (MW <sub>th</sub> )	25.4	25.4	22.5	26.3	26.1	25.0	23.5	26.5	26.1	24.0
Convection loss (MW <sub>th</sub> )	3.57	3.56	3.34	3.64	3.62	3.53	3.41	3.66	3.62	3.46
Net thermal power to the HTF (MW <sub>th</sub> )	350.0	350.2	126.3	350.2	349.2	275.4	147.1	347.9	312.4	104.5
Peak absorbed flux (kW)	1062	1087	583	1040	1067	1013	670	1047	1019	514
Peak tube wall temperature (K)	1052	1052	1035	1053	1051	1053	1039	1049	1055	10328
Peak fraction of allowable flux	0.94	0.95	0.51	0.91	0.90	0.90	0.62	0.94	0.93	0.48
Max HTF velocity (m/s)	2.75	2.96	1.14	2.97	2.91	2.44	1.35	2.90	2.67	0.93
Receiver pressure drop (MPa)	0.041	0.048	0.007	0.048	0.046	0.032	0.010	0.046	0.039	0.005




# Sodium Receiver Mechanical Analysis

- Implementation of the new “Design Guidance for High Temperature Concentrating Solar Power Components” (ANL-20/03)
- Significantly higher flux limits possible



# Capital Cost Breakdown at Commercial Scale



- Financial assumptions from DOE recommended values
- Further details in the final report [NREL/TP-5700-79323](https://www.nrel.gov/docs/fy18/stp/tp-5700-79323.pdf)

Item	1×50 MW <sub>e</sub> module	100 MW <sub>e</sub> system (2×50 MW <sub>e</sub> )
Heliostat field		
Heliostats	\$ 54,212,373	\$ 108,424,746
Site improvements	\$ 7,228,316	\$ 14,456,633
Sodium receiver	\$ 26,260,650	\$ 52,521,300
Tower	\$ 16,339,938	\$ 32,679,876
Sodium loop		
Sodium valves	\$ 907,980	\$ 1,815,960
Sump tank	\$ 1,252,129	\$ 2,504,259
Inlet vessel	\$ 218,298	\$ 436,597
Purification skid	\$ 298,479	\$ 596,959
Sodium pumps	\$ 3,800,633	\$ 7,601,267
Argon system	\$ 94,999	\$ 189,999
Instrumentation and control	\$ 328,314	\$ 656,628
Additional sodium piping	\$ 1,207,663	\$ 2,415,326
Sodium and salt piping		
Riser <sup>†</sup>	\$ 1,426,598	\$ 2,853,197
Downcomer <sup>†</sup>	\$ 4,533,284	\$ 9,066,568
Salt piping	\$ 697,596	\$ 1,395,192
Salt storage		
Tank and salt costs	\$ 54,968,250	\$ 109,936,501
Cold salt pump	\$ 2,772,615	\$ 5,545,230
Hot salt pump	\$ 2,079,462	\$ 4,158,924
Salt valves	\$ 2,106,720	\$ 4,213,440
N <sub>2</sub> ullage gas system	\$ 2,860,000	\$ 5,720,000
Power block and HXs		
Sodium-to-salt HX	\$ 10,290,385	\$ 20,580,770
Salt-to-CO <sub>2</sub> PHX	\$ 26,576,576	\$ 53,153,151
s-CO <sub>2</sub> power block	\$ 41,025,831	\$ 82,051,663
Direct capital cost subtotal	\$ 261,487,093	\$ 522,974,186
Contingency (10%)	\$ 26,148,709	\$ 52,297,419
Total direct capital cost	\$ 287,635,802	\$ 575,271,604
EPC and owner costs (9%)	\$ 25,887,222	\$ 51,774,444
Land cost	\$ 11,260,647	\$ 22,521,293
Total capital (installed cost)	\$ 324,783,671	\$ 649,567,342



# Pilot-scale Sodium Receiver Design

- Flat “billboard” style design
- Key design criteria:
  - Safety, reliability and structural integrity
  - Similarity with the proposed commercial receiver design
  - Performance
  - Cost

Parameter	Value
Design thermal capacity	1 MW <sub>th</sub>
Design sodium inlet temperature	520°C
Design sodium outlet temperature	740°C
Design total sodium mass flow rate	3.7 kg/s
Flow paths	2
Flow path inlet location	Top of inner-most panel
Flow path outlet location	Bottom of outer-most panel
Panels per flow path	3
Tubes per panel	11
Irradiated length per tube (height of billboard)	1.77 m
Tube wall-to-wall spacing (within panels)	1.2 mm
Tube wall-to-wall spacing (between adjacent panels)	4.0 mm
Tube OD	25.4 mm
Tube thickness	1.65 mm
Tube material	Alloy 740H (seamless)
Tube coating	High performance solar-selective coating
Overall irradiated width of billboard	1.77 m

energy.gov/solar-office

*Do not distribute beyond project team.*






# Pilot-scale Sodium Receiver Performance Modelling


- Performance modelling in Heliosim
- Conservative allowable flux limits
- Maximum tube wall temperature disparities <30 K
- Pilot-scale efficiencies will be lower than commercial-scale

Date	Spring equinox		Summer solstice		Winter solstice	
Hours relative to solar noon	0	+3	0	+3	0	+3
DNI (W/m <sup>2</sup> )	1055	1000	1020	980	960	800
HTF thermal output (kw)	1018	1002	1012	1031	1003	1000
Aperture interception efficiency (%)	85.3	81.3	84.8	78.8	82.7	79.3
Receiver efficiency (%)	83.6	83.4	83.9	83.9	83.5	83.5
Combined interception and receiver efficiency (%)	71.3	67.9	71.1	66.1	69.1	66.2




[energy.gov/solar-office](https://energy.gov/solar-office)

*Do not distribute beyond project team.*





Net flux through the tube crown




Bulk sodium temperature

# Sodium Balance of Plant – Overall Layout



# Sodium Safety and Acceptance



- Safety is core to the success of the sodium pathway and is the highest priority
- System design to minimise risk
  - Sodium contained in or near the tower within an isolation zone
  - Rapid drain back of all sodium to a sump tank if there is an incident
  - Secondary containment in a spill tray
  - The best action plan for fire fighters is likely No Action – let any fire burn out naturally

## Design safety

- Good system design
- Minimized sodium inventory
- Adherence to high quality and performance standards
- Suitable material selections
- Fire safety engineering

## Safety requirements

- Ensure containment, i.e. high integrity against rupture, leakage or corrosion
- Maintain high sodium purity
- Use steel liners & trays over concrete
- Ensure rapid draining
- Early leak detection systems
- Avoid proximity to water
- Separation of sodium and people
- Appropriate PPE

# Sodium Safety and Acceptance

- Learning from the past
  - Review of literature (e.g. Sodium-NaK Engineering Handbook)
  - Understanding of risks (sodium chemistry to human factors)
  - Lessons learnt in design (mainly from nuclear facilities)
  - Review of sodium incidents, what happened, why, lessons learnt
- Learning from experts
  - Sodium suppliers (MSSA)
  - Researchers (Sandia, U. Wisconsin, ANL)
  - Operating labs (KIT, ANL, KAERI)
  - Operating plants (Vast Solar)
  - Use of expert consultants (Creative Engineering, Claude Reed, David Wait)
  - HAZMAT experts (NSW Fire Brigade)
- Study visit to Karlsruhe Institute of Technology, Germany, Aug 2017
- Sodium Safety & Handling workshop, Argonne National Lab, Mar 2019
- Technical meeting on Sodium Technologies, KAERI, Daejeon, Korea, Sep 2019
- Sodium Bankability Workshop, Seattle, Feb 2020



ANU visit to KIT sodium loop, Karlsruhe, Germany, Aug 2017



Sodium Safety & Handling workshop, ANL, Mar 2019



# Sodium Safety and Acceptance

- Learning by doing
  - Development of the high-temperature sodium laboratory at ANU
  - Development of the CSIRO and Sandia test loops (in progress)
  - HAZIDs, HAZOPs, FMEA (ANU, CSIRO, Sandia and other partners)
  - Handling sodium (cutting, transport, clean-up)
  - Controlled burning and explosive reactions with water
  - Fire fighting methods and fire extinguishing
  - Experience with different PPE
  - Chemical compatibility testing (e.g. Na, CO<sub>2</sub>, PCMs)
  - Stakeholder engagement (ARENA, EPA, fire services, etc)
  - Training courses



Sodium Fire Training and Demonstration day,  
Canberra 2016



Sodium burn tests at SNL, Jun 2020